




(A-1) KEY FLOOR PLAN 1 WTC 104TH FL.



1.2 EQUIPMENT RELAY BACK DETAIL - 104TH FL.



(A2) TELEPHONE RISER CK. 110TH FL.



A4 S.E. TEL. RISER CR. ON 10ATH FL. CABLE UNDER RAISED FL.

TCA/TAA NO. 3
CONTRACT NO. u
DATE APPROVED: _____

GENERAL NOTES


- (1) STEEL ARMORED FIBER OPT CONTAINING NO PVC. IT WILL CONTRACTOR BY TELEPORT CO. ANY SURPLUS CABLE MUST TELEPORT COMMUNICATIONS
- (2) THE CONTRACTOR SHALL EXCE PULLING CABLE. ANY DAMAGES BY THE CONTRACTOR SHALL EXPENSE.
- (3) ALL PENETRATIONS SHALL AFTER INSTALLATION WITH FIRESTOP COMPOUND.

SCOPE OF WORK

PLACE GLADDED FIBER OPTIC
TO 10ATH FL. IN THE S.E. TEL
AND OUT ACROSS THE 10A
COMPUTER FLOOR. SPLICING
AND 10ATH FL. OPENINGS TO
APPROVED FIRE STOP

job no./drawing no.

FB8029



calvanico associates

2335 victory blvd. n.j. ny 10314 (718) 494-0414

job title/owner

TELEPORT COMMUNICATIONS #1 WORLD TRADE CENTER 110TH TO

[illegible]